



PPG Industries Australia Pty Limited

ABN 82 055 500 939 004

9 Birmingham Avenue Villawood NSW 2163 PO Box 101 Regents Park DC NSW 2143 Australia
Telephone: 61 2 9794 1200 Fax: 61 2 9726 4326

Laboratory Report

VOC Data Sheet

This report is to certify the VOC level of Nawkaw products. VOC is determined by theoretical calculation from the product formula and the subtotal of the known VOC values of the individual raw material components.

Product	VOC by calculation (g/litre)	GBC Limit (g/litre)	Result
Nawkaw Concrete and Masonry Stain	36	50	Conforms

Alan Kesby BSc
Technical Manager
August 2009